



6801 CROSSBOW DRIVE • EAST SYRACUSE, NY USA 13057 315.437.1611

• FAX 315.437.1903 • EMAIL: FLEXHOSE@FLEXHOSE.COM

Standard Specification

(2014Apr 316PC.docx)

RECOMMENDED ENGINEERING SPECIFICATION FOR PumpSaver™ 316 STAINLESS STEEL WETTED BRAIDED METAL PUMP CONNECTOR (FOR STAINLESS STEEL PIPING OF POTABLE WATER)

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. PumpSaver braided metal pump connector(s). Provide appropriate model braided metal pump connector(s) to connect to mating piping:
 - a. Model SSMP6 150# 316/316L stainless steel plate flanges
 - b. Model SSMN6 316 stainless steel male NPT ends
 - c. Model SSVG6 316 stainless steel grooved pipe ends

1.02 MANUFACTURER

- A. PumpSaver braided metal 316 stainless steel wetted pump connector shall be manufactured by Flex-Hose Co. or pre-approved equal.

PART 2 PRODUCTS

2.01 Braided metal pump connector(s)

- A. The hose shall be 316/316L annular corrugated stainless steel (manufactured in the USA).
- B. The braid shall be 304 stainless steel (manufactured in the USA).
- C. The stainless steel ring ferrule or band shall be of not less than 0.048" thick material.
- D. The hose, braid and ferrule shall be integrally seal-welded using a 100% circumferential TIG weld.
- E. The hose shall have the first "lip" removed (on flanged models) to insure there are no sharp edges.
- F. All end fittings shall be must be attached using 100% circumferential weld.
- G. Braided stainless steel pump connectors must be suitable for operating temperatures up to 850 degrees F (455° C).
- H. The rated working pressure of the hose must have a 4:1 safety factor.
- I. Each braided metal hose pump connector is to be individually leak tested by the manufacturer using air-under-water, helium leak detection, and/or hydrostatic pressure.
- J. Model SSMP6 shall be supplied with flat-face 316/316L stainless steel plate flanges with drilling and outside diameter to 150# ANSI.
- K. Model SSMN6 shall be supplied with 316/316L stainless steel schedule 40 male NPT ends.
- L. Model SSVG6 shall be supplied with 316/316L stainless steel schedule 40 groove pipe ends.
- M. Flanged end pump connectors shall be prepared for shipment using cut-to-length spacers, securely positioned between the flanges to prevent axial compression damage during shipment and to maintain the manufactured length.
- N. For the Canadian market they must be CSA standard B51 certified, inspected and tested by the Technical Standards and Safety Authority of Canada.
- O. When used for potable water the models SSMP6, SSMN6 and SSVG6 shall be third party tested and, listed (by a laboratory in compliance with all applicable requirements of ISO/IEC 17025) and marked in accordance with NSF/ANSI 61-2011
- P. When used for potable water the models SSMP6, SSMN6 and SSVG6 shall be third party tested and, listed (by a laboratory in compliance with all applicable requirements of ISO/IEC 17025) and marked in accordance with Section 1417(d) of the Safe Drinking Water Act. Must meet the lead content requirements of Section 116875 of the California Health & Safety Code, and the criteria of NSF/ANSI 372 for low lead.

2.02 WARRANTY

PumpSaver model braided metal pump connector(s) must have a 3-year full product replacement warranty when installed in accordance with all specifications and installation instructions as described by Flex-Hose Co.

www.flexhose.com • 1.877.TRI FLEX

A world of difference in critical piping connections since 1968.™